

TRANSFORMERS

Location and capacity.

HIGH VOLTAGE TRANSFORMERS:				
#	PRIMARY VOLTAGE	SECONDARY VOLTAGE	CAPACITY	LOCATION:
1	13.200	220 -127 V	300 KVA	OFFICE BLDGS. A & B
2	13.200	220 -127 V	300 KVA	WORKSHOPS 1, 2 & TUNNELS
3	13.200	220 -127 V	500 KVA	STAGES 3 & 4
4	13.200	220 -120 V	112.5 KVA	WORKSHOP 3 , ART & WARDROBE DEPTS.
5	13.200	480 -257 V	500 KVA	STAGE 2 (& TANK 2)
6	13.200	480 -257 V	500 KVA	TANK 1
7	13.200	220 -120 V	75 KVA	WORKSHOP 3, LAUNDRY & INFIRMARY
8	13.200	480 -257 V	300 KVA	FILTRATION
9	13.200	480 -257 V	300 KVA	FILTRATION
10	13.200	480 -257 V	500 KVA	DIVE LOCKER
DRY TRANSFORMERS:				
11	480 V	208 -120 V	500 KVA	DIVE LOCKER, TANK 1 SW
12	480 V	208 -120 V	500 KVA	STAGE 2 (& TANK 2)
13	480 V	208 -120 V	500 KVA	TANK 1 NW